

AIRPORT MEMO

To: Chester County Area Airport Authority (CCAAA) Members

From: Gary L. Hudson, Airport Manager

Date: July 1, 2014

Subject: Airport Hot Topics

For your review, below is a listing of issues affecting the Chester County/G.O. Carlson Airport (MQS).

NEW BUSINESS

- * **Career Day:** On May 29th, I was invited to speak at a “Career Day”, which was hosted by the Caln Elementary School.
- * **Apron Drive-thru Gate:** A faulty loop detector caused the gate to intermittently open and close on its own. So, prior to a new detector being delivered and installed, a temporary loop was been installed on May 30th, to correct this issue.
- * **East Drive-thru Gate:** On June 2nd, a new loop detector was installed at this gate.
- * **Terminal HVAC Unit:** The restaurant’s HVAC unit had to be serviced due to the compressor not adequately cooling the restaurant. A Brubaker Technician serviced the unit and discovered that a dead bug inside the unit, disrupted the connection of two copper contactor wires on the compressor. The bug was removed and the contactor was cleaned. The unit was then tested and found to be in good working order.
- * **Pedestrian Gate:** On June 5th, a new Cypher lock was installed on this gate, which is located between Hangars 2 and 3.
- * **Threshold Light:** On June 6th, a light bulb was replaced on the Runway 11 Threshold light.
- * **Kiosk Lights:** On June 10th, the kiosk lights had to be repaired, after vandals disconnected the lights from their fixtures.
- * **Sikorsky Global Helicopters Employee Parking Lot:** On June 10th, 2 potholes were filled in with cold patch in this parking lot.

- * **Weeds Cleared:** On June 11th, weeds were cut and cleared: 1) from the hill bank adjacent to the transient aircraft ramp, 2) along the fence line on the south side of the airport and 3) from the fence line adjacent to Washington Lane.
- * **Men's Bathroom:** On June 11th, a new Fawcett was installed on the sink in the terminal building Men's Bathroom.
- * **Ceiling Vent:** On June 11th, a new ceiling vent with a louver office.
- * **Emergency Generator:** On June 12th, a new Block Heater was installed on the airport emergency generator. control, was installed in my
- * **Runway 29 REILS:** On June 18th, the Runway 29 Runway End Identifier Lights (REILS) were returned to service after a new Controller was installed.

OLD BUSINESS

- * **Storm Drains Repair:** This Project is still in progress.

